



MANITOWOC PUBLIC UTILITIES

1303 South 8th Street P.O. Box 1090 Manitowoc, WI 54221-1090 920-683-4600 FAX 920-686-4348 www.mpu.org

UNSCHEDULED EVENT WDNR NOTIFICATION

To: Randy Matty
WDNR - Air Management
2984 Shawano Ave.
Green Bay, WI 54313

Phone: (920) 662-5158

Fax: (920) 662-5159

Email: randall.matty@wisconsin.gov

From: Manitowoc Public Utilities Power Plant
701 Columbus Street
Manitowoc, WI 54220

MPU Representative: Thomas E. Reed

Phone Number: (920) 686-4384

Date and Time of Notification: August 21, 2013 @ 1130 CDT

Cc: Red Jones – MPU
Jerry Ahlswede – MPU
Brian Fassbender – MPU
Tim Harding – MPU
Tom Reed – MPU
Scott Karbon – MPU
Nilaksh Kothari – MPU

MPU UNSCHEDULED EVENT REPORT

Plant: Manitowoc Public Utilities

Unit No: B09

Event Date: August 20, 2013

Event Time: 1342 CDT

Category: Baghouse Module Failure
 CEM Out of Service
 X Other Reportable Event

Emission Parameter Effected: X Opacity SO₂ NO_x

1) Cause of Event:

B9 fans were being tested in preparation for a scheduled start-up later that evening. The baghouse by-pass damper was not fully closed resulting in a "puff" that did not clear quickly due to the very low flow conditions in the stack.

2) Duration of exceedance, equipment outage and/or unit outage:

There was one six-minute period in which unit opacity was greater than 30 percent on August 20, 2013, 32.5 percent opacity from 1337-1342 (CDT).

3) Time at which correction was completed and/or all excess emissions under control:

Excess emissions were under control on August 20, 2013 at 1343 (CDT) and only one 6-minute exceedance was recorded for the day.

4) Measures taken to minimize emissions during the period:

Procedure was to verify operation of the fans and flows were minimal.

Statement of Completeness: I have reviewed this report in its entirety and, based on information and belief formed after reasonable inquiry, I certify that the statements and information contained are true, accurate and complete.

Print Name: Thomas E. Reed

Title: MPU Environmental Engineer

Signature:

